

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL081007	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 04/13/2016
--	--	---	---

NAME OF PROVIDER OR SUPPLIER RESTWELL HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 401 US 221 S HIGHWAY RUTHERFORDTON, NC 28139
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 000}	Initial Comments Report of Follow-up Survey by Dennis Harrell on 4-13-2016. Some deficiencies were not corrected. Further action is required.	{C 000}		
{C 184}	Fire Safety-Evacuation plan SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0309 PLAN FOR EVACUATION (a) A written fire evacuation plan (including a diagrammed drawing) which has the written approval of the local Code Enforcement Official shall be prepared in large print and posted in a central location on each floor of an adult care home. The plan shall be reviewed with each resident on admission and shall be a part of the orientation for all new staff. (f) This Rule shall apply to new and existing facilities. This Rule is not met as evidenced by: Based on a review of documents, the only evacuation plan posted was out of date and did not include all of the original structure or any of the newer portion of the facility.	{C 184}		
{C 189}	Building Equipment Maintained Safe, Operating SECTION .0300 - PHYSICAL PLANT 10A NCAC 13F .0311 OTHER REQUIREMENTS (a) The building and all fire safety, electrical, mechanical, and plumbing equipment in an adult care home shall be maintained in a safe and operating condition. (k) This Rule shall apply to new and existing	{C 189}		

Division of Health Service Regulation
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE _____ TITLE _____ (X6) DATE _____

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: HAL081007	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING _____	(X3) DATE SURVEY COMPLETED R 04/13/2016
--	--	---	---

NAME OF PROVIDER OR SUPPLIER RESTWELL HOME	STREET ADDRESS, CITY, STATE, ZIP CODE 401 US 221 S HIGHWAY RUTHERFORDTON, NC 28139
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
{C 189}	Continued From page 1 facilities with the exception of Paragraph (e) which shall not apply to existing facilities. This Rule is not met as evidenced by: 1. Based on observation the required one-hour fire rated walls and/or ceilings were compromised in locations. Holes and penetrations that are not sealed with materials approved for use in one-hour fire rated construction present the possibility that a fire that begins in one space can quickly spread to other areas of the facility. Findings include: a. Holes in the basement ceiling.	{C 189}		