

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: FCL012035	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 03/04/2016
--	--	--	---

CONSTRUCTION SECTION

MAR 30 2016

NAME OF PROVIDER OR SUPPLIER
PEACEFUL LIVING

STREET ADDRESS, CITY, STATE, ZIP CODE
**5816 WILLOW POINT DRIVE
MORGANTON, NC 28655**

RECEIVED

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
--------------------	--	---------------	---	--------------------

C 000

Initial Comments

Report by Paul Dixon

DHSR Construction Section conducted a Biennial Survey on March 4, 2016 from 8:50 AM to 10:10 AM at the above referenced facility. DHSR records indicate the home was first licensed on December 8, 2010 as a Family Care Home for six (6) ambulatory Residents (able to evacuate and respond without any physical or verbal assistance during a fire or other emergency). Based on this information we are requiring the home to maintain compliance with the following: the 2005 Rules 10A NCAC 13G for Family Care Homes, the 2009 North Carolina State Building Code - Section 421.2 - Residential Care Homes.

At the time of our visit, we cited deficiencies that require an acceptable plan of correction. They are as follows:

C 000

*From This day 3/22/16
Forward The Staff in
The Facility will check
daily for any clothing
and other objects that
may be behind the
washer and dryer.*

C 174

Building Equipment Maintained Safe, Operating

SECTION .0300 - THE BUILDING
10A NCAC 13G .0317 BUILDING SERVICE EQUIPMENT

(a) The building and all fire safety, electrical, mechanical, and plumbing equipment in a family care home shall be maintained in a safe and operating condition.

(j) This Rule shall apply to new and existing family care homes.

This Rule is not met as evidenced by:
Observations during the survey showed that there is clothing behind the clothes washer and dryer. Remove all clothing and clean from behind the washer and dryer to prevent a fire hazard. Provide the DHSR Construction section with copies of all photographs and any other

C 174

*The staff will also
clean the area behind
the washer and dryer
once a week. This
should comply with
The Rule Section .0300
The Building 10A NCAC
13G .0317 Building Service
Equipment.*

Division of Health Service Regulation
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

Billy Jelf

TITLE

Administrator

(X6) DATE

3-26-16

Division of Health Service Regulation

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: FCL012035	(X2) MULTIPLE CONSTRUCTION A. BUILDING: 01 B. WING: _____	(X3) DATE SURVEY COMPLETED 03/04/2016	
NAME OF PROVIDER OR SUPPLIER PEACEFUL LIVING		STREET ADDRESS, CITY, STATE, ZIP CODE 5816 WILLOW POINT DRIVE MORGANTON, NC 28655		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
C 174	Continued From page 1 supporting documentation concerning this repair.	C 174		

Billy Gog

Administrative

3-26-16



